



11157/22-23

Food Safety Department,
Regional Analytical Laboratory,
Ernakulam.
Dated : 10/05/2022

Description of sample : Well Water
Source : St. Johannes International School, Kakkanad,
Ernakulam, 682 039
Date of Receipt : 04-05-2022
Date of Analysis : Started on 07/05/2022 and completed 09/05/2022
Sample quantity : 125 ml
Physical Appearance : Sample consists of clear water in sterile bottle

Analytical results

Sl. No. (1)	Quality Characteristics (2)	Name of method of test used (3)	Result (4)	Desirable limit prescribed standard as per IS NO. 10500:1991, 2012 (5)
1	Coliforms	IS 1622 1981 RA 2019	<2 MPN/100 ml	<2 MPN/100ml
2	E.Coli	IS 1622 1981 RA 2019	Absent/100 ml	Shall be Absent

Remarks:- ബാക്റ്റീരിയോളജിക്കൽ ക്വാളിറ്റി തൃപ്തികരമാണ്.

Seal

The test report relates to the test items only. No enquires will be entertained after one month issuing test report. Reproduction of test report in part or full without permission is prohibited.



FOOD ANALYST

Q